

PENDANT SYSTEMS

1670 Winchester Rd
PO Box 371
Bensalem PA 19020
PH- 215-638-8552
FAX- 215-638-8554

E-mail: Sales@PendantSystems.com
www.PendantSystems.com

Specification Sheet

PS Part# SC Coil 18/4 & 22/4

Construction:

Conductors: **4-18 AWG 41/34 BC to ASTM B-174**

Nom: **0.048"**

Insulation: **Premium Grade PVC**

Wall: **0.016"**

Nom: **0.08" ± 0.004"**

Color Code: **Black-White-Green-Red**

Construction:

Conductors: **4-22 AWG 26/36 BC to ASTM B-174**

Nom: **0.030"**

Insulation: **Premium Grade PVC**

Wall: **0.016"**

Nom: **0.062" ± 0.004"**

Color Code: **Violet-Violet/White-Gray/White**

Cable: **22 AWG Violet-18 AWG Black-22 AWG-Gray**

22 AWG Gray/White-22 AWG Violet/White Lay: **5/8" LHL**

Nom: **0.235" ± 0.010"**

18 AWG White-18 AWG Green-18 AWG Red with O/A NWT

Note 1: Length of Lay may be adjusted for roundness

Note 2: Overall layout of product rotation of conductors and or pair(s) may vary to insure best possible roundness and look of product

Jacket: **UL AWM QMTT-2 Recognized**

Wall: **0.035"**

Nom: **0.325" ± 0.010"**

Color: **See Note 4**

Note 3: Print/Markings on Product may vary to better suit Industry approvals. Print Shall be indented

*Note 4: This Specification Covers Jacket Colors White-Black-Gray-*Clear *(has foil shield)*

E174416 RU AWM 20811 105°C 600V or 2661 105°C 300V VW-1 cRU AWM I/II A 105°C 600V FT-1

Wire Processed Under Pendant Systems UL Wire Process # E325558



Approvals: **RoHS**

**UL 2661/20811 CSA
REACH Regulation**

**AWM Rating: 300V-600V/105°C
California Prop 65**

"This Cable Design is the intellectual property of Pendant Systems Mfg. intended for use by Pendant Systems Mfg. and their customers. Treat this as a confidential controlled document"

Proprietary information

THIS DOCUMENT CAN ONLY BE DUPLICATED WITH THE WRITTEN PERMISSION FROM PENDANT SYSTEMS MFG.

Note All O.D.'s Are NOM