

PENDANT SYSTEMS

Specification Sheet

1670 Winchester Rd
PO Box 371
Bensalem PA 19020
PH- 215-638-8552
FAX- 215-638-8554

E-mail: Sales@PendantSystems.com
www.PendantSystems.com

PS Part# SC MB 18/4 600V

Construction:

Conductors: **4-18 AWG (16/30) BC**

Nom: **0.049"**

Insulation: **SR-PVC**

Wall: **0.015"**

Nom: **0.079" ± 0.002"**

Color Code: **Black-White-Green-Red**

Cable: **4/C Cabled Around FR Poly Filler**

Lay: **Left**

Nom: **0.195" ± 0.010"**

Shield: **Braided Tinned Copper, 85% Coverage**

Nom: **0.215" ± 0.010"**

Jacket: **Pressured PVC**

Wall: **0.030"**

Nom: **0.285" ± 0.010"**

Color: **Clear**

Note 1: Print/Markings on Product may vary to better suit Industry approvals

Note 2: Print Shall be indented

RU AWM E54661 105°C 600V CSA AWM LL54185 I/II A/B 105°C 600V FT-2

Wire Processed Under Pendant Systems UL Wire process # E325558



Approvals: **RoHS**

AWM 2586

105°C 600V

"This Cable Design is the intellectual property of Pendant Systems Mfg. intended for use by Pendant Systems Mfg. and their customers. Treat this as a confidential controlled document"

Proprietary information

THIS DOCUMENT CAN ONLY BE DUPLICATED WITH THE WRITTEN PERMISSION FROM PENDANT SYSTEMS MFG.

Note All O.D.'s Are NOM