

PENDANT SYSTEMS

Specification Sheet

1670 Winchester Rd
PO Box 371
Bensalem PA 19020
PH- 215-638-8552
FAX- 215-638-8554

E-mail: Sales@PendantSystems.com
www.PendantSystems.com

PS Part# SC Coil 18/5 Clear SJT

Construction:

Conductors: **5-18 41/34 BC**

Nom: **0.045"**

Insulation: **19920 PVC**

Wall: **0.016"**

Nom: **0.077" ± 0.004"**

Color Code: **Black-White-Green-Purple-Gray**

Cable: **5/C Cabled Around Solid Filler with O/A AMA**

Lay: **3.00 LHL** Nom: **0.212" ± 0.010"**

Note 1: Conductor Rotation to be As shown As Cable Pays Off Reel

Jacket: **Clear**

Wall: **0.038"**

Nom: **0.356" ± 0.010"**

Color: **Clear**

Note 2: Print/Markings on Product may vary to better suit Industry approvals

Note 3: Print Shall be indented

E174416 RU AWM 2661 105°C 300V VW-1 cRU I/II A 105°C 600V FT-1

Wire Processed Under Pendant Systems UL Wire Process # E325558



Approvals: **RoHS**

UL

CSA

SJT

Rating: 105°C –300V&600V

"This Cable Design is the intellectual property of Pendant Systems Mfg. intended for use by Pendant Systems Mfg. and their customers. Treat this as a confidential controlled document"

Proprietary information

THIS DOCUMENT CAN ONLY BE DUPLICATED WITH THE WRITTEN PERMISSION FROM PENDANT SYSTEMS MFG.

Note All O.D. 's Are NOM